

TEST REPORT

Electrostatics
Standard test methods for specific applications
Electrical resistance of floor coverings and installed floors

Report Reference No.: 313963TRFEnvEx

Tested by
(name, function and signature): M. Grassi (Project Handler)



Approved by
(name, function and signature): R. Spanevello (Verifier)



Date of issue: 2016-09-30

Testing Laboratory: **Nemko Spa.**

Address: Via del Carroccio 4
I – 20853 Biassono (MB)

Testing location/ address: Nemko Spa., Via del Carroccio 4 I - 20853 Biassono (MB)

Applicant's name: **PPG Univer Spa**

Address: Via Monte Rosa, 7 – 28010 Cavallirio (NO) – Italy

Test specification:

Standard: EN 61340-4-1: 2004

Non-standard test method: N/A

Test Report Form No.: TRF EN 60068-2-ENV

TRF Originator: Nemko S.p.A.

Master TRF: 2016-05

Nemko Spa, I-20853 Biassono (MB). All rights reserved.

This publication may be reproduced in whole for non-commercial purposes as long as the Nemko Spa is acknowledged as copyright owner and source of the material. Nemko Spa takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

Test item description: **Conductive paint**

Trade Mark: PPG Univer Spa

Manufacturer: PPG Univer Spa

Model/Type reference: Epofloor antistatico

This test report may not be partially reproduced, except with the prior written permission of Nemko Spa
The test report merely corresponds to the test sample.
The phase of sampling / collection of equipment under test is carried out by the customer.

Test Report No. :

313963TRFEnvEx

Short description of the EuT		Copy of marking plate
Conductive paint		Not provided
Number of tested samples:	5	
Serial number:	313963 1/6, 313963 2/6, 313963 4/6, 313963 5/6, 313963 6/6 (assigned by Nemko Spa)	
Brand	PPG Univer	
Manufacturer	PPG Univer Spa	
Model	Epofloor antistatico	
Manufacturer year	Not provided	
Ratings	Not provided	
Accessories and detachable parts included/ Mounted tool:	The E.U.T. is composed by a single unit, accessories as supplied in the appliance (EuT tested in the configuration supplied by manufacturer).	
Other options included:	None	
Testing		
Date of receipt of test sample:	2016-09-19	
Testing commenced on:	2016-09-27	
Testing concluded on:	2016-09-29	
The results contained in this report reflect the results for this particular model and serial number. It is the responsibility of the manufacturer to ensure that all production models meet the intent of the requirements detailed within this report.		

Test Result according to the customer criteria of acceptance in § 4.4:	N/A
--	------------

PROJECT HISTORY		
Report number	Modification to the report / comments	Date
313963TRFEnvEx	First release	2016-09-30
--	--	--
REMARKS		

Contents

1	TEST PERFORMED	4
2	TEST STANDARDS AND PROCEDURES	4
3	GENERAL REMARKS	4
3.1	ENVIRONMENTAL CONDITIONS	4
3.2	MEASUREMENT UNCERTAINTY	4
4	EQUIPMENT UNDER TEST	5
4.1	POWER SUPPLY SYSTEM UTILISED	5
4.2	EUT OPERATION MODE:	5
4.3	EUT CONFIGURATION:	5
4.4	ACCEPTANCE CRITERIA	5
5	TEST CONDITIONS AND RESULTS	5
5.1	RESISTANCE MEASUREMENTS	5
6	TEST EQUIPMENT	9
7	PHOTO DOCUMENTATION	10

1 TEST PERFORMED

The following test(s) are performed for qualification purpose, according to EN 61340-4-1:

- Point-to-point resistance (see §5.1.3)
- Vertical resistance (see §5.1.4)
- Resistance to ground (see §5.1.5)

2 TEST STANDARDS AND PROCEDURES

- **NEMKO WM L0177:**
General routines for using instruments at Nemko
- **NEMKO WM L1002:**
Measurement Uncertainty - Policy and Statement
- **EN 61340-4-1:2004**
Electrostatics – Part 4-1: Standard test methods for specific applications – Electrical resistance of floor coverings and installed floors

3 GENERAL REMARKS

3.1 Environmental conditions

Unless different values are declared in the test case, following ambient conditions apply for the tests:

Ambient Temperature: 21 - 25° C
 Relative Humidity: 9 - 15 %
 Atmospheric pressure: 980 - 1060 hPa

3.2 Measurement uncertainty

The measurement uncertainty was calculated for all measurements listed in this test report according to Nemko Spa Technical Procedure WM L1002 and is documented in the quality system acc. to EN 17025. The manufacturer has the sole responsibility of continued compliance of the device.

Hereafter the best measurement capability for Nemko Spa laboratory is reported:

Test	Range	Measurement uncertainty
Temperature	-70 ÷ 180 °C	1,8 °C
Relative Humidity	10 ÷ 98 %	6 %
Resistance	100 mΩ ÷ 10 MΩ	2 %
AC/DC Voltage	10 mV ÷ 1000 V; 0 ÷ 5 kHz	1,5 %
AC/DC Current	0,1 mA ÷ 5 A; 0 ÷ 1 kHz	1,5 %
Time	10 ms ÷ 100 s	1 %
Length	0 ÷ 200 mm	0,08 mm
	0,2 ÷ 8 m	1 %

The reported expanded uncertainty of measurement is stated as standard uncertainty multiplied by the coverage factor $k = 2$ which has been derived from assumed normal probability distribution with infinite degrees of freedom and for a coverage probability of 95%.

4 EQUIPMENT UNDER TEST

4.1 Power supply system utilised

Not supplied. The equipment is a conductive paint.

4.2 EUT operation mode:

All tests have been performed with the samples lying horizontally.

Before testing, the samples were conditioned in climatic chamber for 48 h in climatic chamber with a temperature of 23°C and a relative humidity of 12%.

4.3 EuT configuration:

The EUT has been tested as provided by customer.

Two specimens with dimensions 1200 mm \pm 50 mm by 500 mm \pm 50 mm (for point-to-point and resistance to ground measurements) and three specimens of dimensions 500 mm \pm 50 mm square (for vertical resistance).

The conductive paint samples were applied on drywall pieces.

4.4 Acceptance Criteria

N/A

5 TEST CONDITIONS AND RESULTS

5.1 Resistance measurements

Instruments used: see section 6.

5.1.1 Description of the test location

Test location: Nemko Spa

5.1.2 Photo documentation of the test set-up



Fig.1: The equipment and the two measuring electrodes used for the tests



Fig.2: The measuring electrodes positioning on the specimen during the measurement

5.1.3 Test according to EN 61340-4-1 §9.2 – Point-to point resistance:

The test specimen with its use-surface uppermost is placed on insulating plate. The two measuring electrodes are placed on the sample at 300 mm distance centre to centre for the first measure, then 100 mm centre to centre for the other measurements. A total of six measurements per specimen shall be made, with the electrodes no closer than 100 mm from any previous measurement position.

5.1.3.1 Test Results

Set voltage : 10 V
 Sample: 313963 5/6
 Duration measurement: 15 s

Distance centre-to-centre	Resistance
300 mm	$4,26 \times 10^4 \Omega$
100 mm	$2,54 \times 10^4 \Omega$
100 mm	$2,66 \times 10^4 \Omega$
100 mm	$2,33 \times 10^4 \Omega$
100 mm	$2,57 \times 10^4 \Omega$
100 mm	$2,48 \times 10^4 \Omega$
Geometric mean	$2,74 \times 10^4 \Omega$

Set voltage : 10 V
 Sample: 313963 4/6
 Duration measurement: 15 s

Distance centre-to-centre	Resistance
300 mm	$3,13 \times 10^4 \Omega$
100 mm	$2,26 \times 10^4 \Omega$
100 mm	$1,84 \times 10^4 \Omega$
100 mm	$1,47 \times 10^4 \Omega$
100 mm	$2,23 \times 10^4 \Omega$
100 mm	$2,22 \times 10^4 \Omega$
Geometric mean	$2,14 \times 10^4 \Omega$

Remarks and/or Deviations: None.

5.1.4 Test according to EN 61340-4-1 §9.3 – Vertical resistance:

The specimen is placed on a stainless steel plate (counter-electrode), which is placed on the insulating plate. One measuring electrode is placed on the test specimen with its centre no closer than 100 mm to the specimen's edges. The counter-electrode is connected to the resistance measuring apparatus. A total of six measurements per specimen shall be made, with the electrodes no closer than 100 mm from any previous measurement position.

5.1.4.1 Test Results

Set voltage : 100 V
 Sample: 313963 2/6
 Time measurement: 15 s

Distance centre-to-edges	Resistance
≥100 mm	1,40 x 10 ⁷ Ω
	1,47 x 10 ⁷ Ω
	1,45 x 10 ⁷ Ω
	1,39 x 10 ⁷ Ω
	1,62 x 10 ⁷ Ω
	1,33 x 10 ⁷ Ω
Geometric mean	1,44 x 10 ⁷ Ω

Set voltage : 10/100 V
 Sample: 313963 1/6
 Time measurement: 15 s

Distance centre-to-edges	Resistance
≥100 mm	2,48 x 10 ⁷ Ω
	4,58 x 10 ⁵ Ω
	1,67 x 10 ⁷ Ω
	1,32 x 10 ⁶ Ω
	1,98 x 10 ⁷ Ω
	1,72 x 10 ⁵ Ω
Geometric mean	2,10 x 10 ^{6,2} Ω*

Set voltage : 100 V
 Sample: 313963 6/6
 Time measurement: 15 s

Distance centre-to-edges	Resistance
≥100 mm	3,58 x 10 ⁷ Ω
	2,03 x 10 ⁷ Ω
	2,21 x 10 ⁷ Ω
	3,92 x 10 ⁷ Ω
	2,89 x 10 ⁷ Ω
	2,07 x 10 ⁷ Ω
Geometric mean	2,69 x 10 ⁷ Ω

Remarks and/or Deviations: The set of measurements on sample 313963-1 cannot be considered reliable, the surface of the sample is not uniform and visible scars are present on it.

5.1.5 Test according to EN 61340-4-1 §9.4 – Resistance to ground:

The test specimen with its use-surface uppermost is placed on insulating plate. One measuring electrode is placed on the test specimen with its centre no closer than 100 mm to any of the test specimen's edges. The groundable point is connected to the measuring apparatus. A total of six measurements per specimen shall be made, with the electrodes no closer than 100 mm from any previous measurement position.

At least one measurement per specimen shall be made directly above the groundable point and one measurement per specimen with the electrode positioned 1000 mm from the groundable point.

5.1.5.1 Test Results

Set voltage : 10 V
 Sample: 313963 4/6
 Duration measurement: 15 s

Distance centre-to-centre	Resistance
1000 mm	$1,25 \times 10^5 \Omega$
0 mm	$0,90 \times 10^5 \Omega$
≥100 mm from edges	$0,98 \times 10^5 \Omega$
	$1,12 \times 10^5 \Omega$
	$1,20 \times 10^5 \Omega$
	$1,21 \times 10^5 \Omega$
Geometric mean	$1,02 \times 10^5 \Omega$

Set voltage : 10 V
 Sample: 313963 5/6
 Duration measurement: 15 s

Distance centre-to-centre	Resistance
1000 mm	$1,36 \times 10^5 \Omega$
0 mm	$0,97 \times 10^5 \Omega$
≥ 100 mm from edges	$1,09 \times 10^5 \Omega$
	$1,26 \times 10^5 \Omega$
	$1,02 \times 10^5 \Omega$
	$1,41 \times 10^5 \Omega$
Geometric mean	$1,17 \times 10^5 \Omega$

Remarks and/or Deviations: None.

5.1.6 Measurements test results:

Type of measurement	Resistance (geometric mean)
Point-to-point	$2,42 \times 10^4 \Omega$
Vertical	$1,96 \times 10^7 \Omega$
Point-to-ground	$1,09 \times 10^5 \Omega$

6 TEST EQUIPMENT

Description	Manufacturer	Model	Serial number
Climatic chamber	Espec	ARS 1100	4100000067
Surface resistance measuring apparatus	Charleswater	99026	1420001
Tape measure	Stanley	5 m	33-720
Thermo hygrometer	Data Logger	175 -H2	20012247/305
Barometer	MSR Electronic	MSR145B	330080

7 PHOTO DOCUMENTATION



- END OF TEST REPORT -